

FIRE APPARATUS AND WATER TANK INSPECTIONS

6814

(No.148 July 2014)

Water Tank Inspections are to be performed every four years and prior to the expiration of the new fire engine water tank warranty on all coated steel, stainless steel and polypropylene water tanks as directed in the Mobile Equipment Management Pamphlet 6805 Vehicle Maintenance Procedure and Record. The tank inspection prior to the expiration of the warranty period is to ensure all warranty items and claims will be honored. The tank inspection shall be recorded in the Mobile Equipment Management Pamphlet 6805 Vehicle Maintenance Procedure and Record.

FORMS AND/OR FORMS SAMPLES: RETURN TO ISSUANCE HOME PAGE FOR FORMS/FORMS SAMPLES SITE LINK.

[\(see next section\)](#)

[\(see Table of Contents\)](#)